中国检验检疫科学研究院

检科测试集团
CAIQTEST Group

检验检测报告

INSPECTION AND TEST REPORT

报告编号：BJSHJ24000437

样品名称	废气
检测类别	委托检测
委托单位	北京绿色动力再生能源有限公司

重要声明

Important Statement

signature is incomplete, altered, increased or deleted, this report shall be invalid.

3. 本报告中委托方信息、样品信息均由委托方提供并确认，由委托方承担证实信息准确性、完整性的责任。

the client is responsible to verify the accuracy and completeness of such information.

4. 委托方自行送检的样品，检测结果仅适用于收到的样品，与被测样品取样的来源无关。

to the source of tested samples.

5. 未加盖资质认定标志（CMA）的检验检测报告，不具有对社会的证明作用，仅作为科研、教学或内部质量控制之用。

The test report without qualification certification logo (CMA) shall have no function of proof to the society, and may be only used for scientific research, teaching or internal quality control.

Without the approval of CAIQTEST, this report may not be reproduced (except as reproduced in whole).

7. 未经本单位书面同意，不得将此报告用于商业性及不当宣传。

Without the written consent of CAIQTEST, this report may not be used for commercial or improper propaganda.

8. 对检验检测报告有异议的，应当自收到检验检测报告之日起十五日内向本单位书面提出，未提出、逾期提出、未以书面形式提出的，均视为无异议。

If you have any objection about the test report, please put forward the objection to CAIQTEST within fifteen days after the receipt of the report. If you do not put forward, fail to put forward as scheduled, or fail to put forward in writing, you will be deemed to have no objection.

地址：北京经济技术开发区西环南路18号, 100176

Address: No.18 Xihuan South Road, BDA, Beijing,100176

电话：400-006-1100

Tel: 400-006-1100

网址: www.ticcn.cn

Website: www.ticcn.cn

检验检测报告

委托单位	[illegible]		
委托单位联系人	王[illegible]		
委托单位联系信息	北京市密云区[illegible]镇[illegible]村南山南		
受理日期	2024年[illegible]月[illegible]日	检测日期	2024年[illegible]月[illegible]日

检验检测报告

样品名称	废气

检测结果

样品	样品编号	检测项目	单位	检测值	折算浓度	排放速	折算	单项
[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]
[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]

检验检测报告

报告编号：BJSHJ24000437

样品名称	废气								
检测结果									
样品标识	检测项目	单位	检测值				折算浓度（mg/m³）	排放速率（kg/h）	折算浓度标准值	单项结论
			第一次	第二次	第三次	平均值				
	样品编号	/	BJSHJ24000437007	BJSHJ24000437008	BJSHJ24000437009	/	/	/	/	/
	钴		0.0000433	0.0000201	0.0000321	0.0000318	0.0000291	1.7×10^{-6}	/	/
	锰		0.000997	0.000371	0.000642	0.000670	0.000615	3.7×10^{-5}	/	/
	镍		0.00115	0.000815	0.000835	0.000933	0.000854	5.1×10^{-5}	/	/
	铅		0.000558	<0.000200	0.000315	0.000325	0.000297	1.8×10^{-5}	/	/
	砷		<0.000200	<0.000200	<0.000200	<0.000200	<0.000183	$<1.1\times10^{-5}$	/	/
	汞		<0.000200	0.000286	<0.000200	<0.000200	<0.000183	$<1.1\times10^{-5}$	/	/
	镉、铊及其化合物		/	/	/	0.00000800	0.00000732	4.4×10^{-7}	0.1	符合
	锑、砷、铅、铬、钴、铜、锰、镍及其化合物		/	/	/	0.00395	0.00361	2.2×10^{-4}	1.0	符合
	样品编号	/	BJSHJ24000437010	BJSHJ24000437011	BJSHJ24000437012	/	/	/	/	/
	标干流量	m^3/h	55342	54428	53924	54565	/	/	/	/
	流速	m/s	18.8	18.6	18.4	18.6	/	/	/	/
	烟气温度	℃	166.7	166.8	166.8	166.8	/	/	/	/

样品名称	废气

检测结果

样品标识	检测项目	单位	检测值 第一次	第二次	第三次	平均值	折算浓度（mg/m³）	排放速率（kg/h）	折算浓度标准值	单项结论
	样品	/	BJSHJ24000	BJSHJ24000	BJSHJ24000	/	/	/	/	/
	流量	m³/h	47023	43939	43090	44891	/	/	/	/
	镉		0.0000229	0.00000839	<0.00000800	0.0000118	0.0000106	5.3×10^{-7}	/	/
	铊		<0.00000800	<0.00000800	<0.00000800	<0.00000800	<0.00000719	$<3.6\times10^{-7}$	/	/
	铅		0.00125	0.00130	0.00209	0.00188	0.00832	4.2×10^{-4}	/	/
	砷		0.000152	0.000101	0.000549	0.000267	0.000239	1.2×10^{-4}	/	/
	锑		0.00236	0.00225	0.00457	0.00306	0.00165	1.5×10^{-3}	/	/
	锡		0.00536	0.00421	0.00731	0.00563	0.00314	2.8×10^{-3}	/	/
	镍		0.00643	0.00131	<0.00030	0.00258	0.00584	1.3×10^{-3}	/	/
	铜		0.00474	0.00274	<0.00030	0.00259	0.00595	1.3×10^{-3}	/	/
	锰		<0.0003	<0.0003	<0.0003	<0.0003	<0.00027	$<1.4\times10^{-4}$	/	/

检验检测报告

样品名称	废气									
检测结果										
样品标识	检测项目	单位	检测值					折算浓度（mg/m³）	排放速率（kg/h）	折算浓度标准值	单项结论
			第一次	第二次	第三次	第四次	平均值				
1#烟囱排放口D	样品编号	/	BJSHJ2400437020	BJSHJ2400437021	BJSHJ2400437022	BJSHJ2400437023	/	/	/	/	/
	标干流量	m³/h	53119	53119	53119	53119	53119	/	/	/	/
	烟气流速	m/s	18.3	18.3	18.3	18.3	18.3	/	/	/	/
	烟气温度	℃	168.6	168.6	168.6	168.6	168.6	/	/	/	/
	含氧量	%	10.4	9.7	9.1	9.6	10.4	/	/	/	/
A001	氮氧化物		133	117	139	140	132	117	7.0	300	符合
	二氧化硫		6	<3	15	7	7	7	0.39	100	符合
	一氧化碳		<3	<3	<3	<3	<3	<3	<0.16	100	符合
2#烟囱排放口D	样品编号	单位	BJSHJ24004370023	BJSHJ24004370024	BJSHJ24004370025	BJSHJ24004370026	/	/	/	/	/
	标干流量		48170	48170	48170	48170	48170	/	/	/	/
	烟气流速	/	16.1	16.1	16.1	16.1	16.1	/	/	/	/
	烟气温度	m³/h	167.6	167.6	167.6	167.6	167.6	/	/	/	/
	含氧量	%	8.4	7.7	8.1	8.9	8.3	/	/	/	/
002	二氧化硫		24	33	32	55	36	28	1.7	100	符合
	一氧化碳		17	<3	<3	45	16	13	0.78	100	符合

---本页以下空白---

检验检测报告

附件 1：质控信息